

Table of Contents

07.02.06 - RULES CONCERNING UNIFORM PLUMBING CODE

000. LEGAL AUTHORITY.	2
001. TITLE AND SCOPE.	2
002. WRITTEN INTERPRETATIONS.	2
003. ADMINISTRATIVE APPEALS.	2
004. -- 010. (RESERVED).	2
011. ADOPTION OF 1991 UNIFORM PLUMBING CODE.	2
012. -- 999. (RESERVED).	3

**IDAPA 07
TITLE 02
Chapter 06**

07.02.06 - RULES CONCERNING UNIFORM PLUMBING CODE

000. LEGAL AUTHORITY.

In accordance with Section 54-2605(1), Idaho Code, the Idaho Plumbing Board shall make, promulgate, and publish such rules as may be necessary for carrying out the provisions of this act in order to effectuate the purposes thereof and for the orderly and efficient administration thereof, and except as may be limited or prohibited by law and the provisions of this act, such rules so made and promulgated shall have the force of statute. (2-26-93)

001. TITLE AND SCOPE.

These rules shall be cited as IDAPA 07, Title 02, Chapter 06, Rules Concerning Uniform Plumbing Code, Division of Building Safety. These rules prescribe the use of the Uniform Plumbing Code. (2-26-93)

002. WRITTEN INTERPRETATIONS.

This agency has no written interpretations of this chapter. (2-26-93)

003. ADMINISTRATIVE APPEALS.

This chapter does not provide for administrative relief of the provisions contained herein. (2-26-93)

004. -- 010. (RESERVED).

011. ADOPTION OF 1991 UNIFORM PLUMBING CODE.

The 1991 Uniform Plumbing Code, including Appendix "E" and the installation standards for polybutylene hot and cold water distribution tubing systems, is adopted with the following amendments. (12-29-91)

01. Part 1. Administration. Delete the fee schedule (Table A). (12-29-91)
02. Section 403C - Underground Drainage Piping. No portion of the drainage system installed underground or below a basement or cellar shall be less than two (2) inches in diameter. (12-16-82)
03. Section 406A - Cleanouts. A full-sized accessible cleanout shall be installed at the base or above floor level in each vertical waste or soil stack. A full-size cleanout extending to or above finished grade line shall be installed at the junction of the building drain and the building sewer. (ref.: Section 1107a) Cleanouts shall be installed at fifty (50) foot intervals in horizontal drain lines two (2) inches IPS or smaller. (12-16-82)
04. Section 1004a - Materials. Portion relating to polybutylene pipe is amended to provide that such materials may be used for hot and cold water distribution systems within a building, or cold water distribution systems outside of a building. Crosslinked Polyethylene (PEX) Tubing manufactured to ASTM - F876/F877 and tested, approved, and listed to ANSI/NSF 14 and 61, for potable water, and Crosslinked Polyethylene, Aluminum, Crosslinked Polyethylene (PEX/AL/PEX) along with Polyethylene, Aluminum, Polyethylene (PE/AL/PE) manufactured to ASTM - F1281/F1282 and tested, approved, and listed to the ANSI/NSF 61, for potable water, along with all applicable installation standards. (7-1-97)
05. Table 4-3. Maximum unit loading and maximum length of drainage and vent piping. (EXCEPTION) The building drain and building sewer is not less than four (4) inches IPS extending from its connection with the city or private sewer system and shall run full size to inside the foundation or building lines (ref: Section 1105). (12-16-82)
06. Section 613. Exception - Vertical Wet Venting. A horizontal wet vent may be created provided it is created in a vertical position and all other requirements of Section 613 are met. (8-25-88)
07. Section 1119(b). Every cesspool, septic tank and seepage pit which has been abandoned or has been discontinued otherwise from further use or to which no waste or soil pipe from a plumbing fixture is connected, shall have the sewage removed therefrom and be completely filled with earth, sand, gravel, concrete or other approved material, if required by the Administrative Authority. (8-25-88)

08. Section 1119(e). Where disposal facilities are abandoned consequent to connecting any premises with the public sewer, the permittee making the connection shall fill all abandoned facilities if required by the Administrative Authority within 30 days from the time of connecting to the public sewer. (8-25-88)

09. Section 608(c). No domestic dishwashing machine in a non-residential installation shall be directly connected to a drainage system or food waste disposer without the use of an approved dishwasher airgap fitting on the discharge side of the dishwashing machine. Listed airgaps shall be installed with the flood level (FL) marking at or above the flood level of the sink or drainboard, whichever is higher. (8-25-88)

012. -- 999. (RESERVED).