

Table of Contents

**07.02.06 - RULES CONCERNING UNIFORM PLUMBING CODE
DIVISION OF BUILDING SAFETY**

000.LEGAL AUTHORITY.	2
001.TITLE AND SCOPE.....	2
002.WRITTEN INTERPRETATIONS.....	2
003.ADMINISTRATIVE APPEALS.	2
004. -- 010. (RESERVED).	2
011.ADOPTION OF 2000 UNIFORM PLUMBING CODE.	2
012. -- 999. (RESERVED).	3

**IDAPA 07
TITLE 02
Chapter 06**

**07.02.06 - RULES CONCERNING UNIFORM PLUMBING CODE
DIVISION OF BUILDING SAFETY**

000. LEGAL AUTHORITY.

In accordance with Section 54-2605(1), Idaho Code, the Idaho Plumbing Board shall make, promulgate, and publish such rules as may be necessary for carrying out the provisions of this act in order to effectuate the purposes thereof and for the orderly and efficient administration thereof, and except as may be limited or prohibited by law and the provisions of this act, such rules so made and promulgated shall have the force of statute. (2-26-93)

001. TITLE AND SCOPE.

These rules shall be cited as IDAPA 07.02.06, "Rules Concerning Uniform Plumbing Code," Division of Building Safety. These rules prescribe the use of the Uniform Plumbing Code. (2-26-93)

002. WRITTEN INTERPRETATIONS.

This agency has no written interpretations of this chapter. (2-26-93)

003. ADMINISTRATIVE APPEALS.

This chapter does not provide for administrative relief of the provisions contained herein. (2-26-93)

004. -- 010. (RESERVED).

011. ADOPTION OF 2000 UNIFORM PLUMBING CODE.

The 2000 Uniform Plumbing Code, including Appendices "A, B, C, D, E, G, H, I, J, and L," is adopted with the following amendments. (7-1-01)T

01. Section 218. Delete definition of "Plumbing System." Incorporate definition of "Plumbing System" as set forth in Section 54-2604, Idaho Code. (7-1-01)T

02. Section 420.0. Pressure balance or thermostatic mixing valves are not required for high flow (over eight (8) g.p.m.) tub filler valves with hand shower sets attached. (7-1-01)T

03. Section 604.1. Materials. Crosslinked Polyethylene (PEX) Tubing manufactured to ASTM – F876/F877 and tested, approved, and listed to ANSI/NSF 14 and 61, for potable water, and Crosslinked Polyethylene, Aluminum Crosslinked Polyethylene (PEX/AL/PEX) along with Polyethylene, Aluminum, Polyethylene (PE/AL/PE) manufactured to ASTM – F1281/F1282 and tested, approved, and listed to the ANSI/NSF 61, for potable water along with all applicable installation standards may be used for hot and cold water distribution systems within a building or cold water distribution systems outside of a building. Listed PE (polyethylene) water service and yard piping may be installed within a building (above ground and below ground) with one (1) joint, provided that only listed and approved metallic transition fittings shall be used. (7-1-01)T

04. Section 609.10. Water hammer. Does not apply to residential construction. (7-1-98)

05. Table 6-4 And Table A-2. Change fixture unit loading value for bathtub or combination bath/shower, and clotheswashers to two (2) fixture units. (7-1-01)T

06. Table 7-3. Maximum unit loading and maximum length of drainage and vent piping. (EXCEPTION) The building drain and building sewer is not less than four (4) inches extending from its connection with the city or private sewer system and shall run full size to inside the foundation or building lines (ref: Section 717.0). Change fixture unit loading value for clotheswashers, domestic to two (2) fixture units. (7-1-01)T

07. Section 703.1 - Underground Drainage And Vent Piping. No portion of the drainage or vent system installed underground, underground under concrete or below a basement or cellar shall be less than two (2) inches in diameter. (7-1-01)T

08. Section 703.2 And 710.5. Add Exception. In single family dwellings, one (1) fixture unit may be

allowed for each gallon per minute of flow from a pump or a sump ejector. (7-1-01)T

09. Section 704.2. Double sanitary tees may be used for back to back or side by side fixture trap arms without increasing the barrel size. (7-1-98)

10. Table 7-5. Change fixture unit loading value for one and a half (1 1/2) inch horizontal drainage to two (2) fixture units. (7-1-98)

11. Section 707.4 Cleanouts. A full-sized accessible cleanout shall be installed in the vertical immediately above the floor or at the base of each waste or soil stack. A full-size cleanout extending to or above finished grade line shall be installed at the junction of the building drain and the building sewer (ref.: Section 719.1). Cleanouts shall be installed at fifty (50) foot intervals in horizontal drain lines two (2) inches or smaller. (7-1-01)T

12. Sections 722.2, 722.3, 722.4, 722.5, and 722.6. Delete. (7-1-01)T

13. Section 807.4. A domestic dishwashing machine may be installed without the use of an airgap if the drain hose is looped to the bottom side of the counter top and secured properly. (7-1-01)T

14. Section 908. Exception - Vertical Wet Venting. A horizontal wet vent may be created provided it is created in a vertical position and all other requirements of Section 908 are met. (7-1-98)

15. Section 1002.3. Trap arms may not exceed one hundred eighty (180) degrees without the use of a cleanout. (7-1-01)T

012. -- 999. (RESERVED).

Subject Index

A

Adoption Of 1997 Uniform Plumbing
Code 2

S

Section 707.4 Cleanouts 3
Section 908. Exception- Vertical Wet
Venting 3

T

Table 6-4 2
Table 7-3 2
Table 7-5 3