

# ***Table of Contents***

---

## **07.02.06 - Rules Concerning Uniform Plumbing Code Division of Building Safety**

000. Legal Authority. ....	2
001. Title And Scope. ....	2
002. Written Interpretations. ....	2
003. Administrative Appeals. ....	2
004. -- 010. (Reserved). ....	2
011. Adoption And Incorporation By Reference Of The 2003 Uniform Plumbing Code. ....	2
012. -- 999. (Reserved). ....	3

**IDAPA 07  
TITLE 02  
CHAPTER 06**

**07.02.06 - RULES CONCERNING UNIFORM PLUMBING CODE  
DIVISION OF BUILDING SAFETY**

**000. LEGAL AUTHORITY.**

In accordance with Section 54-2605(1), Idaho Code, the Idaho Plumbing Board shall make, promulgate, and publish such rules as may be necessary for carrying out the provisions of this act in order to effectuate the purposes thereof and for the orderly and efficient administration thereof, and except as may be limited or prohibited by law and the provisions of this act, such rules so made and promulgated shall have the force of statute. (2-26-93)

**001. TITLE AND SCOPE.**

These rules shall be cited as IDAPA 07.02.06, "Rules Concerning Uniform Plumbing Code," Division of Building Safety. These rules prescribe the use of the Uniform Plumbing Code. (2-26-93)

**002. WRITTEN INTERPRETATIONS.**

This agency has no written interpretations of this chapter. (2-26-93)

**003. ADMINISTRATIVE APPEALS.**

This chapter does not provide for administrative relief of the provisions contained herein. (2-26-93)

**004. -- 010. (RESERVED).**

**011. ADOPTION AND INCORPORATION BY REFERENCE OF THE 2003 UNIFORM PLUMBING CODE.**

The 2003 Uniform Plumbing Code, including Appendices "A, B, D, E, G, H, I, J, and L," (herein U.P.C.) is adopted and incorporated by reference with the following amendments. The 2003 Uniform Plumbing Code is available at the Division of Building Safety, 1090 E. Watertower St., Meridian, Idaho 83642; and at the Division of Building Safety, 1250 Ironwood Dr., Ste. 220, Coeur d'Alene, Idaho 83814. (4-6-05)

**01. Section 218.** Delete definition of "Plumbing System." Incorporate definition of "Plumbing System" as set forth in Section 54-2604, Idaho Code. (3-15-02)

**02. Section 316.1.6.** PVC DWV may be joined by the use of one-step solvent cement listed or labeled per U.P.C. Section 301.1.1. (4-6-05)

**03. Section 420.0.** Pressure balance or thermostatic mixing valves are not required for high flow (over eight (8) g.p.m.) tub filler valves with hand shower sets attached. (3-15-02)

**04. Section 421.0.** Delete. (4-6-05)

**05. Section 508.2.** Delete. (4-11-06)

**06. Section 604.1. Materials.** Crosslinked Polyethylene (PEX) Tubing manufactured to ASTM – F876/F877 and tested, approved, and listed to ANSI/NSF 14 and 61, for potable water along with all applicable installation standards may be used for hot and cold water distribution systems within a building or cold water distribution systems outside of a building. Listed PE (polyethylene) water service and yard piping may be installed within a building (above ground and below ground) with one (1) joint, provided that only listed and approved metallic transition fittings shall be used. (4-6-05)

**07. Section 609.4.** Testing. Deleting the phrase "Except for plastic piping," at the beginning of the third sentence and add the following sentence at the end of the section: Plastic piping is to be tested in accordance with manufacturer's installation standards. (4-6-05)

**08. Section 609.10.** Water hammer. Does not apply to residential construction. (7-1-98)

**09. Table 6-4 and Table A-2.** Change fixture unit loading value for bathtub or combination bath/

shower, and clotheswashers to two (2) fixture units. (3-15-02)

**10. Section 610.2.** All new one (1) and two (2) family residences must have a pre-plumbed water softener loop. The kitchen sink must have one (1) hot soft line and one (1) cold soft line and one (1) cold hard line. Exterior cold hose bibbs intended for irrigation purposes must be piped with hard water. Provisions must be made for the discharge of the water softener to terminate in an approved location. (5-3-03)

**11. Section 611.4.** Sizing of Residential Softeners. Amend Footnote 3 to read: Over four (4) bathroom groups, softeners shall be sized according to the manufacturer's standards. (4-6-05)

**12. Table 7-3.** Maximum unit loading and maximum length of drainage and vent piping. (EXCEPTION) The building drain and building sewer is not less than four (4) inches extending from its connection with the city or private sewer system and shall run full size to inside the foundation or building lines (ref: Section 717.0). Change fixture unit loading value for clotheswashers, domestic to two (2) fixture units. (3-15-02)

**13. Section 703.1 - Underground Drainage and Vent Piping.** No portion of the drainage or vent system installed underground, underground under concrete or below a basement or cellar shall be less than two (2) inches in diameter. (3-15-02)

**14. Section 703.2 and 710.5. Add Exception.** In single family dwellings, one (1) fixture unit may be allowed for each gallon per minute of flow from a pump or a sump ejector. (3-15-02)

**15. Section 704.2.** Two inch (2") and smaller double sanitary tees may be used for back to back or side by side fixture trap arms without increasing the barrel size. (4-6-05)

**16. Section 704.3.** Delete. (5-3-03)

**17. Table 7-5.** Change fixture unit loading value for one and a half (1 1/2) inch horizontal drainage to two (2) fixture units. (7-1-98)

**18. Section 707.4 Cleanouts.** A full-sized accessible cleanout shall be installed in the vertical immediately above the floor or at the base of each waste or soil stack. A full-size cleanout extending to or above finished grade line shall be installed at the junction of the building drain and the building sewer (ref.: Section 719.1). Cleanouts shall be installed at fifty (50) foot intervals in horizontal drain lines two (2) inches or smaller. (3-15-02)

**19. Section 712.1.** In the first sentence, delete the phrase "except that plastic pipe shall not be tested with air". (4-6-05)

**20. Section 801.2.3.** Add: Food preparation sinks, pot sinks, scullery sinks, dishwashing sinks, silverware sinks, commercial dishwashing machines, silverware-washing machines, steam kettles, potato peelers, ice cream dipper wells, and other similar equipment and fixtures must be indirectly connected to the drainage system by means of an air gap. The piping from the equipment to the receptor must not be smaller than the drain on the unit, but it must not be smaller than one (1) inch (twenty-five point four (25.4) mm). (5-3-03)

**21. Section 807.4.** A domestic dishwashing machine may be installed without the use of an airgap if the drain hose is looped to the bottom side of the counter top and secured properly. (3-15-02)

**22. Section 908. Exception -- Vertical Wet Venting.** A horizontal wet vent may be created provided it is created in a vertical position and all other requirements of Section 908 are met. (7-1-98)

**23. Section 1002.3.** Trap arms may not exceed one hundred eighty (180) degrees of horizontal turn without the use of a cleanout. (3-15-02)

**012. -- 999. (RESERVED).**

# ***Subject Index***

## **U**

Uniform Plumbing Code 2