

Table of Contents

07.02.06 - Rules Concerning Idaho State Plumbing Code

000. Legal Authority.	2
001. Title And Scope.	2
002. Written Interpretations.	2
003. Administrative Appeals.	2
004. -- 010. (Reserved)	2
011. Adoption And Incorporation By Reference Of The Idaho State Plumbing Code.	2
012. -- 999. (Reserved)	6

**IDAPA 07
TITLE 02
CHAPTER 06**

07.02.06 - RULES CONCERNING IDAHO STATE PLUMBING CODE

000. LEGAL AUTHORITY.

In accordance with Section 54-2605(1), Idaho Code, the Idaho Plumbing Board shall make, promulgate, and publish such rules as may be necessary for carrying out the provisions of this act in order to effectuate the purposes thereof and for the orderly and efficient administration thereof, and except as may be limited or prohibited by law and the provisions of this act, such rules so made and promulgated shall have the force of statute. (2-26-93)

001. TITLE AND SCOPE.

01. Title. These rules shall be cited as IDAPA 07.02.06, "Rules Concerning Idaho State Plumbing Code," Division of Building Safety. (3-25-13)

02. Scope. These rules prescribe the use of the Idaho State Uniform Plumbing Code. (3-25-13)

002. WRITTEN INTERPRETATIONS.

In accordance with Section 67-5201(19)(b)(iv), Idaho Code, this agency may have written statements that pertain to the interpretation of the rules of this chapter, or to compliance with the rules of this chapter. Any such documents are available for public inspection and copying at cost at the Idaho Division of Building Safety offices. (3-29-17)

003. ADMINISTRATIVE APPEALS.

This chapter does not provide for administrative relief of the provisions contained herein. (2-26-93)

004. -- 010. (RESERVED)

011. ADOPTION AND INCORPORATION BY REFERENCE OF THE IDAHO STATE PLUMBING CODE.

The Idaho State Plumbing Code published in 2017, including Appendices "A, B, C, D, E, G, I, J, K and L," (herein ISPC) is adopted and incorporated by reference with amendments as prescribed by the Idaho Plumbing Board and contained in this Section. The Idaho State Plumbing Code is modeled after the 2015 Uniform Plumbing Code (UPC). The Idaho State Plumbing Code is available at the Division of Building Safety offices located at 1090 E. Watertower St., Suite 150, Meridian, Idaho 83642; 1250 Ironwood Dr., Ste. 220, Coeur d'Alene, Idaho 83814; and 2055 Garrett Way, Building 1, Suite 4, Pocatello, Idaho 83201. It may also be accessed electronically online at <http://dbs.idaho.gov/>. (3-29-17)

01. Section 105.3 Testing of Systems. (3-29-17)

a. Delete and replace the following: Plumbing systems shall be tested and approved in accordance with this code or the Authority Having Jurisdiction. Tests may be conducted in the presence of the Authority Having Jurisdiction or the Authority Having Jurisdiction's duly appointed representative. (3-29-17)

b. No test or inspection shall be required where a plumbing system, or part thereof, is set up for exhibition purposes and has no connection with a water or drainage system. In cases where it would be impractical to provide the required water or air tests, or the presences of the Authority Having Jurisdiction, or for minor installations and repairs, the Authority Having Jurisdiction, in accordance with procedures established thereby, shall be permitted to make such inspection as deemed advisable in accordance with the intent of this code. Joints and connections in the plumbing system shall be gastight and watertight for the pressures required by the test. (3-29-17)

02. Section 218 Definitions. Delete definition of "Plumbing System." Incorporate definition of "Plumbing System" as set forth in Section 54-2604, Idaho Code. (3-29-17)

03. Section 314.4 Excavations. Add: Where unsuitable or soft material is encountered, excavate to a depth not less than two (2) pipe diameters below the pipe and replace with select backfill. Such backfill shall be sand, fine gravel, or stone and shall provide lateral support for the pipe. Where rock is encountered, the trench shall be

excavated to a minimum depth of six (6) inches (152 mm) below the bottom of the pipe. Sand shall be added to provide uniform bedding and support for the pipe. The pipe shall not rest on any rock at any point, including joints. (3-29-17)

04. Section 401.2 Qualities of Fixtures. Replace with the following: Plumbing fixtures shall be constructed of dense, durable, non-absorbent materials and shall have smooth, impervious surfaces, free from unnecessary concealed fouling surfaces. (3-29-17)

05. Section 403.3 Exposed Pipes and Surfaces. Delete. (3-29-17)

06. Section 407.4 Transient Public Lavatories. Self-closing or self-closing metering faucets may be installed on lavatories intended to serve the transient public, such as those in, but not limited to, service stations, train stations, airports, restaurants, convention halls, and rest stops. Installed metered faucets shall deliver a maximum of zero point two six (0.26) gallons (one point zero (1.0) liter) of water per use. (3-29-17)

07. Section 408.5 Finished Curb or Threshold. Delete the last sentences of the first paragraph and replace with the following: The finished floor of the receptor shall slope uniformly from the sides toward the drain not less than one-eighth (1/8) inch per foot (20.8 mm/m), nor more than one-half (1/2) inch per foot (41.8 mm/m). (3-29-17)

08. Section 408.7.5 Tests for Shower Receptors. Delete. (3-29-17)

09. Section 409.4 Limitation of Hot Water in Bathtubs and Whirlpool Bathtubs. Delete. (3-29-17)

10. Section 503.1 Inspection of Chimneys or Vents. Add the following to the end of section 503.1: Water heating appliances using Category 3 or 4 exhaust venting shall be tested in its entirety with five (5) pounds of air for fifteen (15) minutes. Plastic vents shall be constructed using manufacturer's instructions. (3-29-17)

11. Section 507.2 Seismic Provisions. Delete. (3-29-17)

12. Section 507.13 Installation in Garages. Replace 507.13 with the following: Any plumbing appliance or appurtenance in residential garages and in adjacent spaces that open to the garage and are not part of the living space of a dwelling unit shall be installed so that burners, burner-ignition devices or other sources of ignition are located not less than eighteen (18) inches (450 mm) above the floor unless listed as flammable vapor ignition resistant. (3-29-17)

13. Table 603.2 Backflow Prevention Devices, Assemblies and Methods. (3-29-17)

a. Delete from the table the entire row related to freeze resistant sanitary yard hydrant devices. (3-29-17)

b. Delete the backflow preventer for Carbonated Beverage Dispensers text from the first column of the table and replace with the following: Backflow preventer for Carbonated Beverage Dispensers (Reduced Pressure Principle Backflow Prevention Assembly). (3-29-17)

14. Section 603.5.12 Beverage Dispensers. Delete and replace with the following: Potable water supply to beverage dispensers, carbonated beverage dispensers, or coffee machines shall be protected by an air gap or a Reduced Pressure Principle Backflow Prevention Assembly in accordance with ASSE 1013. For carbonated beverage dispensers, piping material installed downstream of the backflow preventer shall not be affected by carbon dioxide gas. (3-29-17)

15. Section 603.5.17 Potable Water Outlets and Valves. Delete. (3-29-17)

16. Section 603.5.21 Chemical Dispensers. Add the following new section 603.5.21: The water supply to chemical dispensers shall be protected against backflow. The chemical dispenser shall comply with ASSE 1055 or the water supply shall be protected by one of the following methods: (3-29-17)

- a. Air gap; (3-29-17)
- b. Atmospheric vacuum breaker (AVB); (3-29-17)
- c. Pressure vacuum breaker backflow prevention assembly (PVB); (3-29-17)
- d. Spill-resistant pressure vacuum breaker (SVB); or (3-29-17)
- e. Reduced-pressure principle backflow prevention assembly (RP). (3-29-17)
- 17. Section 605.6.2 Mechanical Joints.** Add to the end of the section the following: Listed PE (polyethylene), one hundred sixty (160) psi minimum, water service and yard piping may be installed within a building (above ground and below ground) with one (1) joint, provided that only listed and approved metallic transition fittings shall be used. Polyethylene (PE) plastic pipe or tubing and fitting joining methods shall be installed in accordance with the manufacturer's installation instructions. (3-29-17)
- 18. Section 609.1 Installation.** Delete the following sentence: Building supply yard piping shall be not less than twelve (12) inches (305 mm) below the average local frost depth; and replace it with the following: The cover shall be not less than forty-two (42) inches (1068mm) below grade. (3-29-17)
- 19. Section 609.4 Testing.** Testing. Deleting the phrase "Except for plastic piping," at the beginning of the third sentence and add the following sentence at the end of the section: Plastic piping is to be tested in accordance with manufacturer's installation standards. (3-25-13)
- 20. Section 609.10 Water Hammer.** Does not apply to residential construction. (3-25-13)
- 21. Section 609.11 Pipe Insulation.** Delete. (3-29-17)
- 22. Table 610.3 and Appendix Table A 103.1.** Change fixture unit loading value for both public and private for bathtub or combination bath/shower, and clothes washers to two (2) fixture units. (3-29-17)
- 23. Section 610.2 Pressure Loss.** Add the following: All new one (1) and two (2) family residences built slab on grade or that will have a finished basement at the time of final inspection must have a pre-plumbed water softener loop. The kitchen sink must have one (1) hot soft line and one (1) cold soft line and one (1) cold hard line. Exterior cold hose bibbs intended for irrigation purposes must be piped with hard water. (3-29-17)
- 24. Table 611.4 Sizing of Residential Softeners.** Amend Footnote 3 to read: Over four (4) bathroom groups, softeners shall be sized according to the manufacturer's standards. (3-29-17)
- 25. Section 612.0 Residential Sprinkler System.** Add the following to the end of the first sentence in section 612.1: and the requirements of the Authority Having Jurisdiction (AHJ). (3-29-17)
- 26. Table 702.1 Drainage Fixture Unit Valves (DFU).** Change fixture unit loading value for clothes washers, domestic for private to two (2) fixture units. (3-29-17)
- 27. Section 703.1 Minimum Size.** Add the following at the end of section 703.1: No portion of the drainage or vent system installed underground, underground under concrete or below a basement or cellar shall be less than two (2) inches in diameter. (3-29-17)
- 28. Section 704.2 Single Vertical Drainage Pipe.** Two inch (2") and smaller double sanitary tees may be used for back to back or side by side fixture trap arms without increasing the barrel size. (3-29-17)
- 29. Section 704.3 Commercial Sinks.** Delete. (3-29-17)
- 30. Table 703.2 Maximum Unit Loading and Maximum Length of Drainage and Vent Piping.** Change fixture unit loading value for one and a half (1 1/2) inch horizontal drainage to two (2) fixture units. (3-29-17)

- 31. Section 705.5.2 Solvent Cement Joints.** Add to the end of the section the following: PVC DWV may be joined by the use of one-step solvent cement listed or labeled per U.P.C. Section 301.1.1. (3-29-17)
- 32. Section 707.4 Locations.** Add the following: A clean out shall be installed for double sanitary tees two (2) inches (50 mm) or less in diameter that receive the discharge from fixture connections. Exception in Section 707.4 shall not apply. A full-sized accessible cleanout shall be installed in the vertical immediately above the floor or at the base of each waste or soil stack. A full-size cleanout extending to or above finished grade line shall be installed at the junction of the building drain and the building sewer. Cleanouts shall be installed at fifty (50) foot intervals in horizontal drain lines two (2) inches or smaller. (3-29-17)
- 33. Section 710.3(4) Sewage Ejectors and Pumps.** Add: Exception (4): One (1) pump shall be permitted for “public use” occupancies provided that such tank receives the discharge of not more than one (1) water closet and ten (10) fixture units (See Section 710.9 Alarms). (3-29-17)
- 34. Section 710.5 Size Building Drains and Sewers.** Add the following exception: In single family dwellings, one (1) fixture unit may be allowed for each gallon per minute of flow from a pump or a sump ejector. (3-29-17)
- 35. Section 712.1 Media.** In the first sentence, delete the phrase “except that plastic pipe shall not be tested with air.” (3-25-13)
- 36. Section 717.0 Size of Building Sewers.** Add the following to the end of section 717.1: Exception: The building drain and building sewer is not less than four (4) inches extending from its connection with the city or private sewer system and shall run full size to inside the foundation or building lines. (3-29-17)
- 37. Section 723.0 General.** Delete the following sentence: “Plastic DWV piping systems shall not be tested by the air test method.” (3-29-17)
- 38. Section 801.3.3 Food Handling Fixtures.** Add: Food preparation sinks, pot sinks, scullery sinks, dishwashing sinks, silverware sinks, commercial dishwashing machines, silverware-washing machines, steam kettles, potato peelers, ice cream dipper wells, and other similar equipment and fixtures must be indirectly connected to the drainage system by means of an air gap. The piping from the equipment to the receptor must not be smaller than the drain on the unit, but it must not be smaller than one (1) inch (twenty-five and four tenths (25.4) mm). (3-29-17)
- 39. Section 805.41 General.** Add to the end of the first paragraph the following: Provisions must be made for the discharge of the water softener to terminate in an approved location. The drain line for a water softener must be three-fourths (3/4) inch minimum. A washer box with a dual outlet is an approved location as long as it is on the same floor or one (1) floor below the softener unit and the water softener drain line is a minimum three-fourths (3/4) inch. (3-29-17)
- 40. Section 807.3 Domestic Dishwashing Machines.** A domestic dishwashing machine may be installed without the use of an airgap if the drain hose is looped to the bottom side of the counter top and secured properly. (3-29-17)
- 41. Section 906.1 Roof Termination.** Delete the existing provision and replace with the following: (3-29-17)
- a.** Roof venting. When conventional roof venting is utilized, each vent pipe or stack shall extend through its flashing and shall terminate vertically not less than six (6) inches (one hundred fifty-two (152) mm) above the roof nor less than one (1) foot (three hundred five (305) mm) from any vertical surface. (4-2-08)
- b.** Sidewall venting. When sidewall venting is utilized, the vent shall extend flush with the eaves/gable end, shall turn down using a ninety (90) degree ell, and shall terminate as close to the roof peak as possible. The vent end must be properly screened. Sidewall venting is acceptable on new or remodel construction on cabins, log homes, and residential or commercial buildings. (4-2-08)

- c. Sidewall venting must meet the intent of Section 906.2 of the ISPC. (3-25-13)
- 42. Section 908.1 Vertical Wet Venting.** Add to the end of the section the following: A horizontal wet vent may be created provided it is created in a vertical position and all other requirements of Section 908 of the ISPC are met. (3-29-17)
- 43. Section 909.0 Special Venting for Island Fixtures.** Add: Parameters for the limited use of Air Admittance Valves (A.A.V.). (3-29-17)
- a. An A.A.V. may be used only in residential buildings. (4-2-08)
- b. In remodels, an A.A.V. may be used with island fixtures or remotely located sinks such as in bar, kitchen, or laundry tray locations. An A.A.V. shall not be used in bathroom groups. (4-2-08)
- c. In new construction, an A.A.V. may be used on island fixture sinks. (4-2-08)
- d. Each A.A.V. may be used to vent only one (1) floor. (4-2-08)
- e. Each A.A.V. must be readily accessible. (4-2-08)
- f. The cross-sectional area of venting must remain the same and must meet the largest required building drain. (4-2-08)
- g. An A.A.V. shall only be installed in accordance with the manufacturer's installation standards as per ASSE 1051. (4-2-08)
- h. An A.A.V. may not be used in an attic, crawl space, outside installation, or in connection with chemical or acid waste systems. (4-2-08)
- 44. Section 1002.3 Change of Direction.** Trap arms may not exceed one hundred eighty (180) degrees of horizontal turn without the use of a cleanout. (3-29-17)
- 45. Section 1007.0 Trap Seal Protection.** Delete section 1007.1 and replace with the following: Floor drains or similar traps directly connected to the drainage system and subject to infrequent use shall be protected with a trap seal primer or other approved trap seal protection device, except where not deemed necessary for safety or sanitation by the Authority Having Jurisdiction. Trap seal primers shall be accessible for maintenance. (3-29-17)
- 46. Section 1016.1 Discharge.** Add the following to the end of section 1016.1: Floor drains installed in residential garages shall be permitted to use the interceptor as the fixture trap. (3-29-17)
- 47. Section 1502.1 General.** Add to this section the following paragraph: Plumbing for a gray water system from any fixture up to, but not to include the exterior irrigation system tank shall be inspected by the Authority Having Jurisdiction. The Idaho Department of Environmental Quality (IDEQ) shall have jurisdiction to inspect and approve the installation of the exterior irrigation system tank and all piping therefrom to the point of disposal in accordance with IDAPA 58.01.03, "Individual/Subsurface Sewage Disposal Rules." Gray water system location and design criteria requirements related to irrigation and leaching shall be determined in accordance with the requirements as established by the IDEQ. (3-29-17)

012. -- 999. (RESERVED)

Subject Index

A

Adoption And Incorporation By
Reference Of The Idaho State
Plumbing Code 2

APPROVED